



## *The Quality Chicken People*

### **ALLEN HARIM FOODS, LLC**

Harbeson Plant  
P.O. Box 63  
18752 Harbeson Rd.  
Harbeson, DE 19951  
TEL (302) 684 - 1640 • FAX (302) 684 - 0584



September 13, 2012

Mr. Glenn Davis, Program Manager  
State of Delaware – DNREC  
Division of Water Resources  
Surface Water Discharges Section  
89 Kings Highway  
Dover, Delaware 19901

Re: Permit #DE0000299  
Outfall 001

Dear Mr. Davis:

This letter is to follow up to the September 11, 2012 verbal notification to Chris Cleaver in which the analytical results from August 28, 2012 and September 5, 2012 at Outfall 001 were reported. Per the notification requirements of Part II, Section A.2.b.1 of the referenced permit Allen Harim Foods, LLC, is reporting the following:

#### **Allen's – Harbeson 001 Composite Sample**

Sample Date	Parameter	Results	
8-28-12	Total Phosphorus	7.54 mg/L	Daily Maximum
8-28-12	Total Phosphorus	42.7 lbs/day	Daily Maximum
8-2012	Total Phosphorus	15.6 lbs/day	Monthly Average
9-5-12	Total Phosphorus	6.23 mg/L	Daily Maximum
9-5-12	Total Phosphorus	44.38 lbs/day	Daily Maximum

As shown above Total Phosphorus results for the dates indicated were above the NPDES daily maximum limit of 3.0 mg/L, monthly average of 15.0 lbs/day and daily maximum of 23.0 lbs/day. In house laboratory testing on grab samples indicated slightly elevated Phosphorus results but within compliance limits. Effluent clarity has been excellent with no other parameters out of the ordinary.

Aluminum Chloride feed to the clarifier was investigated. It was found that a partial plug of the feed line to the clarifier existed. This plug in the aluminum chloride feed line was cleared at approximately 0800 hours with dosage rates measured and confirmed to be at our desired set point. It is anticipated that Total Phosphorus results will be back in compliance with the composite sample taken on 9-11-12.

If you should have any questions, please contact me at (302) 684-1640, Ext. 184.

Respectfully submitted,  
ALLEN HARIM FOODS, LLC.

A handwritten signature in cursive script, reading "Michael R. Sausé".

Michael R. Sausé  
Wastewater Manager

*"Preparing Food for our Families"*